



181 US Hwy 46
Mine Hill, NJ 07803
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Keansburg Early Learning Center
142 Port Monmouth Rd
Keansburg, NJ

Performed For:

Keansburg School District
John Furnback
100 Palmer Place
Keansburg, NJ 07734

Prepared By:

LEW Environmental Services, LLC.
181 US Hwy 46
Mine Hill, NJ 07803

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>


Inspection Date: 11/10/2022
Project Number: 221151

Contact Information

Agency

| | |
|-----------------|---|
| Client Contact: | John Furnback |
| Client Name: | Keansburg School District |
| Street Address | 100 Palmer Place Keansburg, NJ 07734 |
| Phone Number: | (732) 787-2007 |

Risk Assessor(s)

| | |
|-------------------|---|
| Site Assessor(s): | Robert Carlucci |
| License: | NJDOH #015821 |
| Signature: |  |
| Date: | November, 21 st 2022 |
| E-Mail | rcarlucci@lewenvironmental.com |

Firm

| | |
|--------------------|---|
| Organization: | LEW Environmental Services, LLC. |
| Certification #: | NJDCA 00015 E |
| Street: | 181 US Hwy 46 |
| City, State & Zip: | Mine Hill, NJ 07803 |
| Phone Number: | 908-654-8068 |
| Web Address: | http://www.lewcorp.com |

Laboratory

| | |
|-----------------------|------------------------------------|
| Organization: | Environmental Hazard Services, LLC |
| Street: | 7469 Whitepine Road |
| City, State & Zip: | Richmond, VA 23237 |
| NJDEP Certification # | VA008 |
| Phone Number: | 800-347-4010 |

Drinking Water Results

On November 10th 2022, Robert Carlucci of LEW Environmental Services, LLC. collected the following number of water samples:

Keansburg Early Learning Center

- 44 first draw samples collected
- 0 samples above the 15ppb action level

The complete list of samples that exceeded the 15ppb limit can be found in Appendix A. The complete list of all sample results can be found in Appendix C. The laboratory results can be found in Appendix E.

Certain outlets could not or were not tested due to various reasons. The following table lists those locations and the reason why samples were not collected.

| School | Sample Location | Reason for not testing. |
|-------------------------|-----------------|-------------------------|
| All outlets were tested | | |

Recommendations

Those outlets where the first draw sample tested below 15ppb are not considered to be elevated and no mitigation is necessary.

For those outlets where the first draw sample exceeds 15ppb the following steps are recommended:

- 1) Immediately discontinue use of the outlets.
- 2) Conduct second draw (flush) samples on these outlets to further delineate source of contamination.

A complete list of recommendations per outlet can be found in Appendix B.

Additional Recommendations

- 1) Follow-up samples should be collected after any remediation efforts in order to determine the efficacy of the work.
- 2) Any of the inoperable/non-functioning outlets listed above that are brought back into service should be sample.
- 3) Comply with all requirements set forth in NJAC 6A:26.

Appendix B Recommendations

| Building | Location | Recommendation |
|---------------------------|----------|----------------|
| No Recommendations Needed | | |

| | | | | | |
|---------------------------------|-------------|-----------------------|------------|------------|-------|
| Learning Center | | | 2022 | 022 | |
| Keansburg Early Learning Center | ELC-S-SB119 | STAFF BATH SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-SB130 | STAFF BATH SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-WF-130 | WATER FOUNTAIN BY 130 | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-BF-130 | BOTTLEFILL BY 130 | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-WC-130 | WATER COOLER BY 130 | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-121 | ROOM 121 SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-BB-121 | ROOM 121 BUBBLER | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-122 | ROOM 122 SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-BB-122 | ROOM 122 BUBBLER | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-128 | ROOM 128 SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-BB-128 | ROOM 128 BUBBLER | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-127 | ROOM 127 SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-BB-127 | ROOM 127 BUBBLER | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-123 | ROOM 123 SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-BB-123 | ROOM 123 BUBBLER | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-124 | ROOM 124 SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-BB-124 | ROOM 124 BUBBLER | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-125 | ROOM 125 SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-BB-125 | ROOM 125 BUBBLER | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-126 | ROOM 126 SINK | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-BB-126 | ROOM 126 BUBBLER | 11/10/2022 | 11/17/2022 | <1.00 |
| Keansburg Early Learning Center | ELC-S-SR | SUN ROOM | 11/10/2022 | 11/17/2022 | <1.00 |



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Report Number: 22-11-02036

Client: LEW Corp
 181 US Hwy 46
 Mine Hill, NJ 07803

Received Date: 11/14/2022
 Reported Date: 11/18/2022
 Sampled By: Robert Carlucci
 Tech Certification #:

Project/Test Address: 221151; Keansburg Early Learning Center; 142 Port Monmouth Rd;
 Keansburg, NJ

Client Number:
 201327

Laboratory Results

Fax Number:
 Ext 18 Melissa

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|-------------------|------------------|-----------------|------------------------------|--------------------------|---------------|--------------|
| 22-11-02036-001 | ELC-S-NO | 11/10/2022 | NURSE OFFICE SINK | 1.10 | 11/17/2022 | |
| 22-11-02036-002 | ELC-BB-NO | 11/10/2022 | NURSE OFFICE BUBBLER | <1.00 | 11/17/2022 | |
| 22-11-02036-003 | ELC-S2-NO | 11/10/2022 | NURSE OFFICE EXAM SINK | 1.75 | 11/17/2022 | |
| 22-11-02036-004 | ELC-S3-NO | 11/10/2022 | BURSE OFFICE SINK | <1.00 | 11/17/2022 | |
| 22-11-02036-005 | ELC-S-DWL | 11/10/2022 | KITCHEN DISH WASH LEFT SINK | 5.55 | 11/17/2022 | |
| 22-11-02036-006 | ELC-S-DWR | 11/10/2022 | KITCHEN DISH WASH RIGHT SINK | <1.00 | 11/17/2022 | |
| 22-11-02036-007 | ELC-S-KTCH | 11/10/2022 | KITCHEN SINK SMALL | 8.67 | 11/16/2022 | |
| 22-11-02036-008 | ELC-S-100C | 11/10/2022 | MAIN OFFICE SINK | 1.62 | 11/17/2022 | |
| 22-11-02036-009 | ELC-S-BMOR | 11/10/2022 | MAIN OFFICE BATHROOM RIGHT | <1.00 | 11/17/2022 | |
| 22-11-02036-010 | ELC-S-BMOL | 11/10/2022 | MAIN OFFICE BATHROOM LEFT | <1.00 | 11/17/2022 | |
| 22-11-02036-011 | ELC-S-SBL | 11/10/2022 | STAFF BATH SINK LEFT | <1.00 | 11/17/2022 | |
| 22-11-02036-012 | ELC-S-SBR | 11/10/2022 | STAFF BATH SINK RIGHT | <1.00 | 11/17/2022 | |

Environmental Hazards Services, L.L.C

Client Number: 201327
 Project/Test Address: 221151; Keansburg Early Learning Center; 142 Port Monmouth Rd; Keansburg, NJ

Report Number: 22-11-02036

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|-------------------|------------------|-----------------|---------------------|--------------------------|---------------|--------------|
| 22-11-02036-033 | ELC-S-128 | 11/10/2022 | ROOM 128 SINK | <1.00 | 11/17/2022 | |
| 22-11-02036-034 | ELC-BB-128 | 11/10/2022 | ROOM 128 BUBBLER | <1.00 | 11/17/2022 | |
| 22-11-02036-035 | ELC-S-127 | 11/10/2022 | ROOM 127 SINK | <1.00 | 11/17/2022 | |
| 22-11-02036-036 | ELC-BB-127 | 11/10/2022 | ROOM 127 BUBBLER | <1.00 | 11/17/2022 | |
| 22-11-02036-037 | ELC-S-123 | 11/10/2022 | ROOM 123 SINK | <1.00 | 11/17/2022 | |
| 22-11-02036-038 | ELC-BB-123 | 11/10/2022 | ROOM 123 BUBBLER | <1.00 | 11/17/2022 | |
| 22-11-02036-039 | ELC-S-124 | 11/10/2022 | ROOM 124 SINK | <1.00 | 11/17/2022 | |
| 22-11-02036-040 | ELC-BB-124 | 11/10/2022 | ROOM 124 BUBBLER | <1.00 | 11/17/2022 | |
| 22-11-02036-041 | ELC-S-125 | 11/10/2022 | ROOM 125 SINK | <1.00 | 11/17/2022 | |
| 22-11-02036-042 | ELC-BB-125 | 11/10/2022 | ROOM 125 BUBBLER | <1.00 | 11/17/2022 | |
| 22-11-02036-043 | ELC-S-126 | 11/10/2022 | ROOM 126 SINK | <1.00 | 11/17/2022 | |
| 22-11-02036-044 | ELC-BB-126 | 11/10/2022 | ROOM 126 BUBBLER | <1.00 | 11/17/2022 | |
| 22-11-02036-045 | ELC-S-SR | 11/10/2022 | SUN ROOM | <1.00 | 11/17/2022 | |

Method: EPA 200.8
 Analyst: Candace Mason
 Accreditation #: NJ VA008

Reviewed By Authorized Signatory:



Tasha Eaddy
 QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
Phone: (800) 347-4010 FAX: (804) 275-4907

ENVIRONMENTAL HAZARDS SERVICES, LLC

ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

Company Name: LEW CORP

Account #: 201327

Address: 181 US Highway 46

City/State/Zip: Mine Hill, NJ 07803

Phone: (908-654-8068

Email: labresults@lewcorp.com

Fax: 908-654-8069

Project Name / Collection Address: Keansburg ELC 142 Port Monmouth Rd

City/State/Zip: Keansburg, NJ

Project #: 22151

Sampled By: Robert Carluci

License # (if Required):

Water Source: (Check One) Public Well

Well Tag # (if Applicable):

| X | 5 Day Turnaround | | 3 Day Turnaround | | 2 Day Turnaround | | 1 Day Turnaround | | LAB USE |
|----|------------------|-----------------------|--|-----------------|--|--------|---------------------------------|-------------------------|---------|
| | No. | Client Sample ID | Collection Location (Ex: Kitchen Sink) | Collection Date | Collection Time | Metals | Field Parameters | Temp at Time of Receipt | |
| 11 | ELC-S-SBL | Staff Bath Sink Left | 11/10/22 | 10:00 AM | Lead <input checked="" type="checkbox"/> | Other | Field pH at time of Collection: | | |
| 12 | ELC-S-SBR | Staff Bath Sink Right | | | | | Temp. at time of Collection: | | |
| 13 | ELC-S-111 | Room 111 Sink | | | | | | | |
| 14 | ELC-S-134 | Room 134 Sink | | | | | | | |
| 15 | ELC-SB-134 | Room 134 Bubblers | | | | | | | |
| 16 | ELC-S-116 | Room 116 Sink | | | | | | | |
| 17 | ELC-SB-116 | Room 116 Bubblers | | | | | | | |
| 18 | ELC-S-117 | Room 117 Sink | | | | | | | |
| 19 | ELC-SB-117 | Room 117 Bubblers | | | | | | | |
| 20 | ELC-S-133 | Room 133 Sink | | | | | | | |

Released by: Robert Carluci

Signature:

Released by: A Smart

Signature:

Robert Carluci
A Smart

Date/Time: 11/10/22 3:04 PM

Date/Time: 11/11/22 11:14 AM

~ For Lab Use Only ~

2036



Water Chain-of-Custody Form

SHIP TO: 7469 Whitepine Rd. Richmond, VA 23237
 Phone: (800) 347-4010 FAX: (804) 275-4907
 ENVIRONMENTAL HAZARDS SERVICES, LLC ONLINE CLIENT PORTAL AVAILABLE FOR ANALYSIS RESULTS AT: www.leadlab.com

~ For Lab Use Only ~

10320

Company Name: LEW CORP Account #: 201327
 Address: 181 US Highway 46 City/State/zip: Mine Hill, NJ 07803
 Phone: (908-654-8068 Email: labresults@lewcorp.com Fax: 908-654-8069
 Project Name / Collection Address: Kearsburg ELC 142 Post Monmouth Rd Kearsburg, NJ
 Project #: 22151 Sampled By: Robert Carluci License # (If Required):

Water Source: (Check One) Public Well Well Tag # (If Applicable):
 (Required)

| No. | Client Sample ID | Collection Location (Exc: Kitchen Sink) | Collection Date | Collection Time | Metals | | | Field Parameters | LAB USE |
|-----|------------------|---|-----------------|-----------------|--------|--------|-------|------------------|-----------------------------|
| | | | | | Lead | Copper | Other | | |
| X | | | | | | | | | 1 Day Turnaround Call Ahead |
| | | | | | | | | | 2 Day Turnaround |
| | | | | | | | | | 3 Day Turnaround |
| 31 | ELC-S-122 | Room 122 Sink | 11/10/22 | 10:00 AM | X | | | | |
| 32 | ELC-BB-122 | Room 122 Bubblers | | | | | | | |
| 33 | ELC-S-128 | Room 128 Sink | | | | | | | |
| 34 | ELC-BB-128 | Room 128 Bubblers | | | | | | | |
| 35 | ELC-S-127 | Room 127 Sink | | | | | | | |
| 36 | ELC-BB-127 | Room 127 Bubblers | | | | | | | |
| 37 | ELC-S-123 | Room 123 Sink | | | | | | | |
| 38 | ELC-BB-123 | Room 123 Bubblers | | | | | | | |
| 39 | ELC-S-124 | Room 124 Sink | | | | | | | |
| 40 | ELC-BB-124 | Room 124 Bubblers | | | | | | | |

Released by: Robert Carluci Signature: *Robert Carluci*
 Released by: A Snow Signature: *A Snow*
 Date/Time: 11/10/22 3:00 AM
 Date/Time: 11/11/22 11:13 AM